

# INDUSTRIAL INSULATION

for Systems Operating Above Ambient Temperature



U.S. Department of Energy  
Energy Efficiency and Renewable Energy  
Office of Industrial Technologies  
Washington, D.C. 20585

From September, 1995 ORNL/M-4678

## Background

This bulletin was prepared to provide readily accessible information about the value to industry of thermal insulation on piping and flat surfaces wherever operating temperatures are above surrounding ambient conditions. Installing thermal insulation can dramatically reduce the thermal energy (heat) lost through these surfaces. Cutting such losses is an economically sound measure in energy conservation programs, and is especially cost effective in facilities where lost heat has value. In addition, for systems operating above 200°F, insulation contributes to worker safety.

Insulation cannot be applied to

Table 1a. Heat-Loss Rates from Uninsulated Surfaces Exposed to a Ten mph Wind  
(Millions of BTUs per linear foot per year)

pipes or flat surfaces without care because it will change temperature distribution within a thermal system by increasing operating temperatures of pipes and walls. The changed temperature distribution regime must be taken into account especially in the case of temperature sensitive processes or materials.

The tables contained in this bulletin offer a tool for quickly estimating possible savings by applying thermal insulation. The tables in this bulletin are a guide to economically justified insulation thicknesses based on calculations listed for specific physical and economic parameters. When large surface areas or high temperatures are involved, however, it is advisable to do an engineering analysis. Programs for this purpose are available through insulation manufacturers and associations. Sources of information are identified on the last page of this bulletin.

## Heat Loss from Uninsulated Surfaces

Identifying the rate of thermal energy (heat) loss from an uninsulated surface is the starting point for understanding the incentive for installing thermal insulation. Tables 1a, 1b, and 1c contain calculated values for the rate of heat loss from horizontal pipes and from either horizontal or vertical flat surfaces. The heat losses are given in millions of BTUs per year for one linear foot of pipe or one square foot of flat

surface. These calculations use published correlations for the outside heat transfer coefficient that include the effects of wind and thermal radiation from the exterior surface.

A heat loss computer program published by the American Society for Testing and Materials (ASTM) was used to calculate losses from insulated surfaces [ref. 1].

Uninsulated surface heat losses were calculated using equations published by Incropera and DeWitt [ref. 2]. The heat-loss rates are based on an ambient temperature of 70°F, a wind speed of 10 MPH, an outside surface emittance of 0.80, and a thermal conductivity for carbon steel of 326 Btu·in/ft<sup>2</sup>·hr·°F at 200°F and 267 Btu·in/ft<sup>2</sup>·hr·°F at 800°F. The input parameters for Table 1b are the same as those for Table 1a except that the wind velocity is zero. Thus, Table 1a represents outdoor conditions while Table 1b represents indoor conditions.

The input parameters used to generate Table 1c are the same as those used for Table 1b except for the surface emittance of 0.9. Comparison of Table 1c and Table 1b shows the effect of surface emittance on the heat-loss rate.

Variations in ambient temperature will change the heat-loss rate if the process temperature remains constant. Figure 1 provides heat-loss multipliers that can be used to calculate heat-loss rates for ambient temperatures below the 70°F standard used for the tables.

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	2.4	6.4	11.2	17.2	25.1	35.3
1	3.1	8.4	15.0	23.6	35.0	50.0
2	4.5	12.4	22.7	36.5	55.4	81.0
3	6.2	16.2	30.0	49.1	75.5	111.5
4	7.4	20.6	36.2	59.9	92.9	138.2
5	8.6	24.1	44.9	71.0	111.0	165.9
6	9.7	27.4	51.4	85.2	128.7	193.2
8	11.7	33.5	63.4	105.9	166.2	243.4
10	13.8	39.7	75.7	127.4	201.0	302.2
12	15.7	45.4	87.0	147.4	233.7	352.8
16	18.7	54.4	105.2	179.5	286.5	434.7
20	22.2	65.2	127.1	218.4	350.7	534.7
24	25.7	76.2	149.6	256.8	414.2	633.8
Flat Surfaces	(millions of BTUs per square foot per year)					
Vertical	2.9	9.0	19.3	36.1	61.5	98.5
Facing up	3.0	9.8	20.8	38.2	64.2	101.9
Facing down	2.8	8.1	17.1	32.8	57.2	93.3

Calculated using emittance 0.8 and ambient temperature 70°F  
 One year is 8320 hours of operation  
 Flat surface calculations used characteristic length of 10 feet

**Table 1b. Heat-Loss Rates from Uninsulated Surfaces with Zero Wind Velocity and 0.8 Exterior Surface Emittance (millions of BTUs per Linear foot per year)**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	0.6	2.2	4.7	8.6	14.4	22.7
1	0.9	3.2	7.1	13.0	21.9	34.6
2	1.5	5.5	12.1	22.5	38.3	60.8
3	2.1	7.7	17.2	32.3	55.1	87.7
4	2.6	9.7	21.7	41.0	70.0	111.5
5	3.2	11.8	26.5	50.0	85.6	136.6
6	3.7	13.8	31.1	59.0	101.1	161.4
8	4.7	17.5	39.8	75.7	130.0	207.6
10	5.7	21.5	48.9	93.2	160.3	256.0
12	6.6	25.1	57.4	109.7	188.9	302.0
16	8.2	31.0	71.2	136.4	235.5	377.1
20	10.0	38.2	87.9	169.0	292.4	469.1
24	11.8	53.2	118.0	201.4	349.2	560.8
Flat Surfaces	(millions of BTUs per square foot per year)					
Vertical	2.3	8.4	18.8	35.4	60.7	97.6
Facing up	2.6	9.5	20.7	38.0	64.0	101.6
Facing down	1.5	6.2	15.0	30.0	53.8	89.2

Calculated using emittance 0.8 and ambient temperature 70°F  
**Table 1c. Heat-Loss Rates from Uninsulated Surfaces with Zero Wind and 0.9 Exterior Surface Emittance (millions of BTUs per linear foot per year)**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	0.6	2.3	5.1	9.4	15.8	24.9
1	0.9	3.5	7.6	14.2	24.0	38.1
2	1.6	5.9	13.1	24.7	42.1	67.2
3	2.2	8.3	18.8	35.5	60.7	96.9
4	2.8	10.5	23.7	45.0	77.2	123.3
5	3.4	12.7	28.9	54.9	94.5	151.1
6	4.0	14.9	34.0	64.8	111.6	178.6
8	5.0	19.0	43.5	83.3	143.6	229.7
10	6.1	23.3	53.5	102.6	177.1	283.3
12	7.2	27.3	62.9	120.9	208.9	334.4
16	8.8	33.8	78.1	150.4	260.5	417.7
20	10.8	41.6	96.5	186.5	323.8	519.9
24	12.8	57.4	128.4	222.5	386.8	621.9
Flat Surfaces	(millions of BTUs per square foot per year)					
Vertical	2.4	9.1	20.5	38.9	67.1	108.3
Facing up	2.8	10.2	22.3	41.5	70.3	112.3
Facing down	1.7	6.9	16.7	33.5	60.1	99.9

Calculated using emittance 0.9 and ambient temperature of 70°F

(a) Exterior surface emittance 0.1  
(b) Exterior emittance 0.8

Nom. Pipe Diameter (inches)		Process Temperature (°F)				
		400 A/B/C	600 A/B/C	800 A/B/C	1000 A/B/C	1200 A/B/C
1	(a)	152/122/109	205/152/131	263/186/155	327/224/182	395/265/212
	(b)	123/102/95	156/120/107	193/141/121	231/163/136	271/187/154
2	(a)	164/128/114	224/163/140	291/203/168	364/246/200	440/293/234
	(b)	130/106/97	168/127/112	209/150/128	253/175/146	297/202/165
4	(a)	174/137/120	242/179/150	316/225/183	396/276/220	480/330/259
	(b)	136/111/100	178/135/117	223/162/136	270/192/157	318/223/179
8	(a)	160/145/126	217/192/159	281/245/197	350/302/238	422/363/283
	(b)	124/115/103	158/142/122	196/172/143	235/204/166	275/238/190
12	(a)	162/148/130	222/197/167	288/252/209	358/312/254	432/374/302
	(b)	125/116/105	160/144/125	197/175/148	237/208/173	278/243/200
16	(a)	170/154/134	235/207/174	306/266/218	382/330/266	461/397/318
	(b)	130/119/107	167/149/129	208/182/153	250/218/180	294/254/208
24	(a)	174/157/137	241/212/178	315/274/224	393/340/274	475/409/328
	(b)	131/120/108	170/152/131	211/186/156	255/222/184	299/260/212
Flat Surfaces		(millions of BTUs per square foot per year)				
Vertical						
	(a)	186/162/148	263/222/197	346/288/252	435/359/312	528/434/376
	(b)	146/129/119	194/166/149	246/206/183	299/249/218	353/293/256
Facing up						
	(a)	173/151/138	240/203/181	315/261/228	395/324/281	480/391/337
	(b)	141/125/116	186/159/144	235/197/175	285/237/208	337/278/243
Facing down						
	(a)	211/184/167	303/258/229	402/338/297	503/423/370	606/510/446
	(b)	154/135/124	207/176/158	263/221/195	320/267/234	376/313/275

Calculated using ambient temperature 80°F and zero wind velocity. First increment of insulation is one inch for flat surfaces and for pipes with nominal diameters of six inches or less; 1.5 inches for larger size diameters.

### Exterior Surface

Safety considerations associated with systems operating at temperatures above ambient can outweigh energy savings. The computer program used to calculate the numbers in the preceding tables was used to calculate exterior surface temperatures for an ambient temperature of 80°F, a wind speed of zero, and an exterior

### Temperatures for Burn

surface emittance of 0.1. The emittance of 0.1 was considered to be representative of aluminum jacketing. An emittance of 0.8 was considered to be representative of non-metallic surfaces. These are not, however, the most severe conditions for determining surface temperatures for personnel protection evaluations.

### Protection

**Table 3** contains surface temperatures for one, two, and three increments of thermal insulation. The entries in **Table 3** are degrees in F in a format A/B/C where A is the calculated temperature for one increment of insulation, B is for two increments, and C is for three increments.

Heat-flow and temperature calculations were used to determine the thicknesses of thermal insulation needed to limit the outside surface temperatures for personnel protection to 125°F for highly conductive (metal) surfaces or 150°F for non-conductive surfaces. **Tables 4a** and **4b** present results for exterior emittances of 0.1 (aluminum jacketing) and 0.8 (nonreflective covering) respectively. Since insulation products are generally available in specific thickness increments, the product thickness that meets or exceeds those shown in

**Tables 4a** and **4b** should be used. If the ambient temperature is greater than 80°F, the exterior surface temperatures will be greater than the values given in **Table 3**. For example, a 10°F change in the ambient temperature will change the exterior surface temperature by about 9°F for pipes three inches or greater in diameter and about 8°F for pipes less than three inches in diameter. Other factors such as solar loading, wet high-conductivity insulation, or new low-emittance jacketing can increase surface temperatures.

**Table 4a. Insulation Thickness Required to Obtain Surface Temperatures Below 125°F with Zero Wind**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	1	2	3	5	7	10
1	1	2	3.5	6	8	>10
2	1	2.5	4.5	7	9	>10
3	1	2.5	5	8	>10	>10
4	1	3	5	8	>10	>10
5	1	3	6	9	>10	>10
6	1	3	6	9	>10	>10
8	1	3.5	6	10	>10	>10
10	1	3.5	7	10	>10	>10
12	1	3.5	7	10	>10	>10
16	1	4	8	>10	>10	>10
20	1	4	8	>10	>10	>10
24	1	4	8	>10	>10	>10
Flat Surfaces						
Vertical	1	4	8	>10	>10	>10
Facing up	1	3	6	10	>10	>10
Facing down	1.5	6	>10	>10	>10	>10

Calculated using emittance 0.1 and ambient temperature 80°F

**Table 4b. Insulation Thickness Required to Obtain Surface Temperatures  
Below 150°F with Zero Wind**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	1	1	1.5	2	2.5	3
1	1	1	1.5	2	2.5	3.5
2	1	1	1.5	2	3	4
3	1	1	1.5	2.5	3.5	4.5
4	1	1	2	2.5	3.5	4.5
5	1	1	2	2.5	4	4.5
6	1	1	2	3	4	5
8	1	1	2	3	4	6
10	1	1	2	3	4.5	6
12	1	1	2	3	4.5	6
16	1	1	2	3.5	4.5	6
20	1	1	2.5	3.5	5	7
24	1	1	2.5	3.5	5	7
Flat Surfaces						
Vertical	1	1	2	3.5	5	7
Facing up	1	1	2	3	4.5	7
Facing down	1	1.5	2.5	4	6	9

Calculated using emittance 0.8 and ambient temperature 80°F

**Table 5a. Economic Thickness of Insulation (inches) with Surface Exposed  
to 10 mph Wind**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	1	1	1.5	2.5	2.5	3
1	1	1.5	2	2.5	3	3
2	1	1.5	2.5	3	3	4
3	1	2	2.5	3	4	4
4	1	2	3	3	4	4
5	1	2	3	4	4	4
6	1.5	2	3	4	4	4
8	1.5	2.5	3	4	4	4
10	1.5	2.5	4	4	4	4
12	1.5	2.5	4	4	4	4
16	1.5	2.5	4	4	4	6
20	1.5	2.5	4	4	4	6
24	1.5	2.5	4	4	4	6
Flat Surfaces						
Vertical	2	3	4	4	6	6
Facing up	2	3	4	4	6	6
Facing down	1.5	3	4	4	6	6

Calculated using emittance 0.1 and ambient temperature 70°F and \$3 per million BTUs

**Economic Insulation Thickness**

A thermal insulation thickness that satisfies an economic assessment of the minimal cost of owning and operating a thermal system is commonly called the economic thickness. Economic thicknesses are determined from the value of energy that is saved, the cost and performance of insulation, and a number of financial factors. A detailed analysis is justified for systems that operate at elevated temperatures or if large surface areas are involved.

Sources of available information for detailed analyses are listed on the back page of this bulletin. A set of calculated economic thicknesses are presented in **Tables 5a, 5b, and 5c**. **Tables 5a-c** contain nominal insulation thicknesses for environmental conditions of 70°F with a wind speed of 10 mph. Since a large fraction of industrial insulation is jacketed, the exterior surface emittance was assigned a value of 0.1. The economic strategy chosen for the calculation was minimization of annual cost for an anticipated life of seven years. Calculations for economic thickness were limited to thickness of ten inches or less.

Given the importance of cost of energy as a factor, three levels of energy cost were considered: \$3 per million BTUs, \$6 per million BTUs, and \$10 per million BTUs. These costs are for energy delivered to the system being considered and should include energy conversion efficiency and other losses. The entries in **Tables 5a, 5b, and 5c** give the calculated economic thicknesses for the three energy costs cited above. The factors used in the economic thickness calculations are shown below.

**Table 5b. Economic Thickness of Insulation (Inches) with Surface Exposed to 10 mph Wind**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	1	1.5	2.5	3	3	3
1	1	2	3	3	4	4
2	1.5	2.5	3	4	4	4
3	1.5	2.5	4	4	4	4
4	1.5	3	4	4	4	6
5	1.5	3	4	4	4	6
6	1.5	3	4	4	6	6
8	1.5	3	4	4	6	6
10	1.5	4	4	4	6	6
12	2	4	4	4	6	6
16	2	4	4	6	6	8
20	2	4	4	6	6	8
24	2	4	4	6	6	8
Flat Surfaces						
Vertical	2.5	4	4	6	10	10
Facing up	2.5	4	4	6	10	10
Facing down	2.5	4	4	6	10	10

Calculated using emittance 0.1 and ambient temperature of 70°F and \$6 per million BTUs

**Table 5c. Economic Thickness of Insulation (Inches) with Surface Exposed to 10 mph Wind**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	1	2.5	3	3	4	4
1	1.5	2.5	3	4	4	4
2	1.5	3	4	4	4	6
3	2	3	4	4	6	6
4	2	3	4	4	6	6
5	2	4	4	6	6	8
6	2	4	4	6	6	8
8	2.5	4	4	6	6	10
10	2.5	4	4	6	9	9
12	2.5	4	4	6	9	10
16	2.5	4	6	6	9	10
20	2.5	4	6	6	9	10
24	3	4	6	6	10	10
Flat Surfaces						
Vertical	3	4	6	10	10	10
Facing up	4	4	6	10	10	10
Facing down	3	4	6	10	10	10

Calculated using emittance 0.1 and ambient temperature 70°F and \$10 per million BTUs

Annual Fuel Inflation Rate.....	6%
Annual Hours of Operation.....	8320
Plant Depreciation Period (years).....	7
New Insulation Depreciation (years).....	7
Incremental Equip. Invest. Rate (\$/MMBTU/hr).....	3.47
Annual Insulation Maintenance (% of new cost).....	2
Plant Maintenance (%).....	1
Interest Rate (%).....	10
Income Tax Rate (%).....	30
Labor Cost (\$/hr).....	38.35
Labor Productivity from FEA [3] report	
Base price of Insulation -	
(\$/ft for two inches of jacketed insulation	
for a nominal 2-inch diameter pipe).....	4.86
(\$/ft for two inches of flat insulation).....	2.31
Material Price adjustment factors from FEA [3] report	

**Table 6** contains the energy savings that result from the application of the Aeconomic thickness insulation. The contents of this table are based on an exterior surface emittance of 0.1, a 10 mph wind, and a 70°F ambient temperature.

The value of saved energy was used to calculate simple payback times for the three levels of energy cost. The simple paybacks in months are listed in **Tables 7a-c**.

**Table 6. Savings in Heat-loss Rate with Economic Insulation Thickness with Surface Exposed to 10 mph Wind (millions of BTUs per linear foot per year)**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200



1/2	2.2	6.0	10.6	16.4	23.9	33.6
1	2.9	8.0	14.4	22.6	33.6	48.2
2	4.3	11.9	21.8	35.3	53.6	78.5
3	5.9	15.5	29.1	47.6	73.3	108.4
4	7.0	20.0	35.1	58.1	90.3	135.4
5	8.2	23.3	43.7	69.0	108.1	162.8
6	9.2	26.6	50.0	82.9	126.1	189.6
8	11.2	32.4	61.7	103.2	163.1	239.2
10	13.2	38.7	73.7	124.2	197.4	297.3
12	15.1	44.2	84.8	143.7	229.7	347.2
16	17.9	53.0	102.4	176.2	281.7	429.3
20	21.3	63.5	123.7	214.5	344.9	528.3
24	24.6	74.2	145.7	252.2	407.5	626.5
Flat Surfaces	(millions of BTUs per square foot per year)					
Vertical	2.8	8.8	18.8	35.5	60.9	97.8
Facing up	2.9	9.5	20.3	37.6	63.7	101.2
Facing down	2.6	7.8	16.6	32.2	56.7	92.6

Calculated using emittance 0.1 and ambient temperature of 70°F and \$6 per million BTUs

**Table 7a. Simple Payback (Months) at Economic Thickness with Surface Exposed to 10 mph Wind**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	12.0	4.5	3.1	2.7	1.8	1.5
1	9.6	4.2	2.9	2.1	1.6	1.1
2	7.5	3.2	2.4	1.7	1.1	1.0
3	6.2	3.4	2.1	1.4	1.2	0.8
4	5.8	2.9	2.2	1.3	1.1	0.7
5	5.5	2.7	1.9	1.6	1.0	0.7
6	6.1	2.6	1.9	1.4	0.9	0.6
8	5.8	2.8	1.7	1.2	0.8	0.5
10	5.6	2.7	2.0	1.2	0.7	0.5
12	5.5	2.6	1.9	1.1	0.7	0.5
16	5.9	2.6	1.9	1.1	0.7	0.8
20	6.1	2.7	1.8	1.1	0.7	0.7
24	6.0	2.6	1.8	1.0	0.6	0.7
Flat Surfaces						
Vertical	12.5	4.6	2.4	1.3	1.1	0.7
Facing up	12.1	4.3	2.2	1.2	1.1	0.7
Facing down	12.3	5.2	2.7	1.4	1.2	0.7

Calculated using emittance 0.1 and ambient temperature 70°F and \$3 per million BTUs

**Table 7b. Simple Payback (Months) at Economic Thickness with Surface Exposed to 10 mph Wind**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	6.0	2.7	2.0	1.5	1.0	0.7

1	4.8	2.5	1.8	1.2	1.1	0.8
2	4.5	2.2	1.3	1.1	0.7	0.5
3	3.7	1.9	1.5	0.9	0.6	0.4
4	3.4	1.9	1.4	0.8	0.5	0.6
5	3.2	1.8	1.2	0.8	0.5	0.6
6	3.1	1.7	1.2	0.7	0.8	0.5
8	2.9	1.6	1.0	0.6	0.7	0.5
10	2.8	1.9	1.0	0.6	0.6	0.4
12	3.3	1.8	0.9	0.6	0.6	0.4
16	3.4	1.8	0.9	0.9	0.6	0.6
20	3.4	1.8	0.9	0.9	0.6	0.5
24	3.4	1.7	0.9	0.9	0.5	0.5
Flat Surfaces						
Vertical	6.7	2.6	1.2	1.0	0.8	0.5
Facing up	6.5	2.4	1.1	0.9	0.8	0.5
Facing down	7.1	2.9	1.4	1.1	0.9	0.5

Calculated using emittance 0.1 and ambient temperature 70°F and \$6 per million BTUs

**Table 7c. Simple Payback (Months) at Economic Thickness with Surface Exposed to 10 mph Wind**

Nom. Pipe Diameter (inches)	Process Temperature (°F)					
	200	400	600	800	1000	1200
1/2	3.6	2.1	1.4	0.9	0.9	0.6
1	3.4	1.7	1.1	1.0	0.7	0.5
2	2.7	1.5	1.1	0.7	0.4	0.6
3	2.6	1.3	0.9	0.6	0.7	0.4
4	2.4	1.1	0.8	0.5	0.6	0.4
5	2.3	1.4	0.7	0.8	0.5	0.5
6	2.2	1.3	0.7	0.7	0.5	0.5
8	2.4	1.2	0.6	0.6	0.4	0.5
10	2.3	1.1	0.6	0.6	0.6	0.4
12	2.2	1.1	0.6	0.6	0.6	0.4
16	2.3	1.1	1.0	0.6	0.6	0.4
20	2.3	1.1	0.9	0.5	0.5	0.4
24	2.6	1.0	0.9	0.5	0.6	0.4
Flat Surfaces						
Vertical	4.3	1.6	1.1	0.8	0.5	0.3
Facing up	4.7	1.4	1.0	0.8	0.5	0.3
Facing down	4.5	1.8	1.2	0.9	0.5	0.3

Calculated using emittance 0.1 and ambient temperature 70°F and \$10 per million BTUs

# INFORMATION SOURCES

## **North American Insulation Manufacturers Association**

3E Plus-Insulation Thickness Computer Program  
44 Canal Center Plaza - Suite 310  
Alexandria, Virginia 22314

## **SofTech<sup>2</sup>**

P.O. Box 55232  
Grand Junction, Colorado 81505

## **National Commercial & Industrial Insulation Standards**

Midwest Insulation Contractors Association  
2017 South 139<sup>th</sup> Circle  
Omaha, Nebraska 68144-2149

## **1993 ASHRAE Handbook-Fundamentals, 20.9-20.10, 22.17-22.19**

American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc.  
1791 Tullie Circle, NE  
Atlanta, Georgia 30329

## **Chemical Engineers= Handbook, 6<sup>th</sup> Edition, 11.55-11.59**

Robert H. Perry and Don W. Green  
Published by McGraw-Hill Book Company  
New York, NY

## **Handbook of Thermal Insulation Design Economics for Pipes and Equipment**

W.C. Turner and J.F. Malloy  
Published by R.F. Krieger, New York (1980)

## **Thermal Insulation Handbook**

W.C. Turner and J.F. Malloy  
Published by McGraw-Hill Book Company, New York (1988)

# References

1. American Society for Testing and Materials, A Standard Practice for Determination of Heat Gain or Loss and the Surface Temperatures of Insulated Pipe and Equipment Systems by the Use of a Computer Program, ≡ (C 680), Philadelphia, PA, 1994 Annual Book of ASTM Standards Vol. 04.06.
2. Frank P. Incropera and David P. DeWitt, *Fundamentals of Heat and Mass Transfer*, 3<sup>rd</sup> Edition, John Wiley and Sons, New York (1990).
3. Federal Energy Administration, A Economic Thickness for Industrial Insulation, ≡ Conservation Paper Number 46, (August 1976).